

APENDIX-L

FORM 'S'

[See Rule 87 (5)]

Fire Audit Report

Year. 2024-25

To

JAIN PUBLIC Hr. SEC. SCHOOL.
NEAR BUS STAND GOPALGANJ
SAGAAR

Sir,

Sub: Submission of Fire Audit Report of Building Name JAIN PUBLIC Hr. SEC. SCHOOL.

I P.K Diwan (B.E FIRE) Have Inspected Your Building / Premises On 13/12/2024 Located at NEAR BUS STAND GOPALGANJ SAGAAR and Checked All Fire Equipment's / Installations and Have Completed the Fire Audit of the Said Building / Premises.

1. Details Of Fire System Installed Are As Below:-

S. No.	Particular	Available / Installed Or Not Installed (As Per Requirements) (Give Comments)	Comments For Working Of System (Attach Details, If Needed)
1.	Access	Yes Proper	Access to All Fire safety Equipment and exits is easy and by norms
2.	Wet Riser	Not Installed	Not Applicable As Per NBC 2016 Part 4
3.	Down Comer	Not Installed	Needs To Be Installed As Per NBC 2016 Part 4
4.	Hose Reel	Not Installed	Needs To Be Installed As Per NBC 2016 Part 4
5.	Automatic Sprinkler System	Not Installed	Not Applicable As Per NBC 2016 Part 4
6.	Yard Hydrant	Not Installed	Not Applicable As Per NBC 2016 Part 4
7.	Underground Tank With Draw Off Connection	Not Installed	Not Applicable As Per NBC 2016 Part 4
8.	Terrace Tanks	Yes 5000 Ltr	10000 Ltr. Needs To Be Installed As Per NBC 2016 Part 4
9.	Fire Pump	Not Installed	Needs To Be Installed As Per NBC 2016 Part 4
10.	Terrace Pump	Not Installed	Needs To Be Installed As Per NBC 2016 Part 4
11.	First Aid Fire Fighting Appliances	Yes Portable Fire Extinguisher	13 Nos. 4 Kg ABC, 1Nos. Co2 4.5 kg, 9 Ltr AFFF 1 Nos.
12.	Pressurization System	Not Installed	Not Applicable As Per NBC 2016 Part 4
13.	Auto Detection System	Not Installed	Not Applicable As Per NBC 2016 Part 4

Director/Secretary
Jain Public Hr. Sec. School
Sagar (M. P.)

Principal
Jain Public Hr. Sec. School
Sagar (M. P.)

Digitally signed by Pradeep Kumar Diw Date: 2024.12.13 12:43:07 +05'30'

14.	Manual Operated Electrical Fire Alarm System	Not Installed	Not Applicable As Per NBC 2016 Part 4
15.	P.A. System With Talk Back Facility	Not Installed	Not Applicable As Per NBC 2016 Part 4
16.	Emergency Light	Yes Installed	As Per NBC 2016 Part 4
17.	Auto D.G. Set/INVERTER	Yes Installed	As Per NBC 2016 Part 4
18.	Illuminated Exit Sign	Yes Installed	Installed As Per NBC 2016 Part 4
19.	Means Of Escape	Yes Provided	As Per NBC 2016 Part 4
20.	Compartmentation	Not Installed	Not Applicable As Per NBC 2016 Part 4
21.	MCB/ELCB	Yes Installed	MCB of Proper ISI Mark And Approved Make
22.	Fireman Switch In Lift	Yes Installed	As Per NBC 2016 Part 4
23.	Hose Boxes With Delivery Hose And Branch	Not Installed	Not Applicable As Per NBC 2016 Part 4
24.	Refuge Area	Yes Provided	Front Side of The Building As Per NBC 2016 Part 4
25.	Any Other Installation	No	No Need Found

It Is Certified That Required Fire System as given above are is necessary and has to be done before Fire certificate.

Date: 13/12/2024

Digitally signed
by Pradeep
Kumar Diwan
Date:
2024.12.13
12:42:46
+05'30'

P.K. Diwan
Signature

Name of Fire Engineer


P.K Diwan

Registered Fire Consultant

Add. : Bhopal

By Order And In The Name Of Governor of Madhya Pradesh.

SHUBHASHISH BANERJEE. Dy. Secy.


Director/Secretary
Jain Public Hr. Sec. School
Sagar (M. P.)


Principal
Jain Public Hr. Sec. School
Sagar (M. P.)